



Test Report issued under the responsibility of:



TEST REPORT
IEC 60269-2
Low-voltage fuses
Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) - Examples of standardized systems of fuses A to K

Report Number: 180301688SHA-002
Date of issue: 2018-04-24
Total number of pages..... 18

Applicant's name.....: YUEQING BARFUSE ELECTRIC CO., LTD
Address: Yonghe san Rd, no.15, Chengdong Industry zone, Yueqing, Zhejiang, China

Test specification:
Standard: IEC 60269-2: 2013 +A1:2016
Test procedure.....: CB Scheme
Non-standard test method.....: N/A

Test Report Form No.....: IEC60269_2C
Test Report Form(s) Originator.....: EZU
Master TRF: Dated 2014-06




Copyright © 2014 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:
The test results presented in this report relate only to the object tested.
This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description	STRIP TYPE FUSE RAIL	
Trade Mark	 BARFUSES <small>BATTLE FOR SAFETY</small>	
Manufacturer	Same as applicant	
Model/Type reference	BTR2	
Ratings	Un=690V, In=250A; Ip=690V/50kA; System C	
Testing procedure and testing location:		
<input checked="" type="checkbox"/> Testing CB Laboratory:	Intertek Testing Services Shanghai	
Testing location/ address	Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China	
<input checked="" type="checkbox"/> Associated CB Testing Laboratory:	Inspection Center of Products' Quality of Low Voltage Electric Apparatus in Zhejiang Province	
Testing location/ address	No. 400 Guangqiong Rd. Jiaxing Zhejiang CHINA	
Tested by (name + signature)	Quiet Lin	
Approved by (name + signature)	Allen Wang	
<input type="checkbox"/> Testing procedure: TMP/CTF Stage 1:		
Testing location/ address		
Tested by (name + signature)		
Approved by (name + signature)		
<input type="checkbox"/> Testing procedure: WMT/CTF Stage 2:		
Testing location/ address		
Tested by (name + signature)		
Witnessed by (name + signature)		
Approved by (name + signature)		
<input type="checkbox"/> Testing procedure: SMT/CTF Stage 3 or 4:		
Testing location/ address		
Tested by (name + signature)		
Witnessed by (name + signature)		
Approved by (name + signature)		
Supervised by (name + signature).....		

List of Attachments (including a total number of pages in each attachment):		
N/A		
Summary of testing:		
Clause	Testing Items	Testing Location
8.1.4	Arrangement of the fuse and dimensions	CBTL
8.1.5.1	Resistance	CBTL
8.2	Verification of the insulating properties and of the suitability for isolation	ACTL
8.3	Temperature rise, power dissipation	ACTL
8.4.3.1	Verification of conventional non-fusing and fusing current	ACTL
8.4.3.2	Verification of rated current of “g” fuse-link	ACTL
8.4.3.3	Verification of time-current characteristics and gates	ACTL
8.4.3.4	Overload	ACTL
8.4.3.5	Conventional cable overload protection	ACTL
8.4.3.6	Operation of Indicating device and striker	ACTL
8.5	Verification of the breaking capacity	ACTL
8.6	Verification of the cut-off current characteristics	ACTL
8.7	Verification of I ² t characteristics and overcurrent discrimination	ACTL
8.8	Degree of protection	CBTL
8.9	Resistance to heat	CBTL
8.10	Non-deterioration of contacts	ACTL
8.11.1	Mechanical strength	ACTL
8.11.2	Miscellaneous test	ACTL

Number of fuse-holder to be tested

Test according to subclause	Number of samples				
	#01	#02	#03		
8.1.4 Dimensions	x				
8.2 Insulating properties and suitability for isolation	x				
8.11.2.2 Resistance to abnormal heat and fire	x				
8.11.1.2 Mechanical strength of the fuse-base		x			
8.3 Temperature rise, power dissipation			x		
8.11.1.1 Mechanical strength of fuse-holder			x		
8.3 Temperature rise, power dissipation			x		
8.10.1.1 Contacts		x			
8.11.1.2 Mechanical strength of the fuse-base		x			
8.5.5.1 Peak withstand current of a fuse-base		x			
8.9 Resistance to heat			x		
8.11.2.4 Non-deterioration of of insulating parts of fuse-link and fuse-base			x		
8.11.1.2 Mechanical strength of the fuse-base			x		
8.10.1.2 Direct terminal clamps ^{b)}					
8.11.2.3 Resistance to rusting		x			

Note:

a) The test sequence is according to IEC 60269-2, Table 302


b) Clause 8.10.1.2 is not applicable, no such direct terminal clamps.

Summary of compliance with National Differences

The products comply with the standard EN 60269-1:2007+A1:2009+A2:2014 and HD 60269-2:2013

Copy of marking plate

Made In China

Product Model:	BTR2-250A	STRIP TYPE FUSE RAIL
Rated voltage:	AC690V50HZ	Rated current: 250A
Applicaton Category	AC-21B	Isolation code: 
Fuse Size:	SIZE I	Dissipated power: 32W

Test item particulars.....:	
Classification of installation and use.....:	Rail installed
Supply Connection.....:	Copper bus-rail with screws and copper conductor with pillar terminals
Fuse system	A/B/C/D/E/F/G/H/I/J/K
Possible test case verdicts:	
- test case does not apply to the test object	N/A
- test object does meet the requirement.....	P (Pass)
- test object does not meet the requirement.....	F (Fail)
Testing	
Date of receipt of test item	2018-03-20
Date (s) of performance of tests	2018-03-20 ~ 2018-04-20
General remarks:	
<p>The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory. "(see Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report.</p> <p>Throughout this report a <input checked="" type="checkbox"/> comma / <input type="checkbox"/> point is used as the decimal separator.</p> <p>This test report is valid only being read together with the test reports of 180301688SHA-001</p> <p>This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.</p>	
Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60269-2:	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable
When differences exist; they shall be identified in the General product information section.	

Name and address of factory (ies) : Same as applicant

General product information:

Un=690V, In=250A;

Ip=690V/50kA; System C; Uimp=6kV

Rated acceptable power dissipation 32W

IEC 60269-2			
Clause	Requirement + Test	Result - Remark	Verdict

Requirements IEC 60269-1			
---------------------------------	--	--	--

FUSE SYSTEM C – FUSE-RAILS (NH FUSE SYSTEM)			
--	--	--	--

5	CHARACTERISTICS OF FUSES		
5.2	Rated voltage (V) as specified	690V (fuse-holder)	P
5.3.2	Rated current (A) of fuse-rails (see Figure 301)	250A	P
5.5.1	Rated power (W) acceptance of fuse-rails (see Figure 301)	32W	P

6	MARKING		
	Markings are legible		P
6.1	Fuse-holder marked by:		--
	- IEC 60269-2.....		P
	- size.....	Size 1	P
	Marking of rated current and rated voltage are discernible from the front		P
6.2	Fuse-links marked by:		--
	- IEC 60269-2.....		N/A
	- size or reference		N/A
	- rated breaking capacity		N/A
	Marking of rated current and rated voltage are discernible from the front		N/A
	Fuse-links are marked as described in Table 104..		N/A

7	STANDARD CONDITIONS FOR CONSTRUCTION		
7.1	Mechanical design Sample: #01		--
	Reference A / Reference B /Reference C	Reference B	P
	dimension marking c max: prescribed (mm); measured (mm)		N/A
	dimension marking d ₁ : prescribed (mm); measured (mm)		N/A
	dimension marking d ₂ min: prescribed (mm); measured (mm)		N/A
	dimension marking h ₁ min: prescribed (mm); measured (mm)	Prescribed: 40 mm Measured: 46 mm	P

IEC 60269-2			
Clause	Requirement + Test	Result - Remark	Verdict
	dimension marking h ₂ max: prescribed (mm); measured (mm)	Prescribed: 175 mm Measured: 142 mm	P
	dimension marking m ₁ : prescribed (mm); measured (mm)	Prescribed: 280-305 mm Measured: 300 mm	P
	dimension marking m ₂ : prescribed (mm); measured (mm)	Prescribed: 185±2,5 mm Measured: 186 mm	P
	dimension marking m ₃ max: prescribed (mm); measured (mm)	Prescribed: 280 mm Measured: 277 mm	P
	dimension marking m ₄ : prescribed (mm); measured (mm)	Not such lug terminals	N/A
	dimension marking m ₅ : prescribed (mm); measured (mm)	Not such lug terminals	N/A
	dimension marking n ₂ max: prescribed (mm); measured (mm)	Prescribed: 100 mm Measured: 98,0 mm	P
	dimension marking r min: prescribed (mm); measured (mm)	Prescribed: 17 mm Measured: 27,1 mm	P
	dimension marking s max: prescribed (mm); measured (mm)	Prescribed: 38 mm Measured: 34,5 mm	P
	dimension marking t min : prescribed (mm); measured (mm)	Prescribed: 21 mm Measured: 31,0 mm	P
	dimension marking v: prescribed (mm); measured (mm)	Prescribed: 80±3 mm Measured: 82,4 mm	P
	dimension marking z max: prescribed (mm); measured (mm)	Prescribed: 5 mm Measured: 3,80 mm	P
7.1.2	Connections, including terminals cross-sectional ranges (Table 301) : torques to be applied (Table 111) (lug terminal) :	Cu, 25 to 120 mm ² M10, 32 Nm	P
7.2	Insulating properties		--
	Creepage distances and clearances of fuses and fuse-accessories meet requirements of IEC 60664-1 for overvoltage category III and pollution degree 3. :		P
8	TESTS		
	IEC 60269-1 applies with the following supplementary requirements		
8.1.6	Testing of fuse-holders		--
	Tested according to Table 302..... :		P

IEC 60269-2			
Clause	Requirement + Test	Result - Remark	Verdict
8.11.1.2	Mechanical strength of the fuse-base (Sample: #02)		--
	Contact force are tested on all three phases of a new fuse-rail		P
	Test-link inserted three times in the fuse-base : (Dimensions of blade contacts see Figure 101) (Withdrawal force F lied within limits in Table118)	Limits: 110~350N Measured: L1: 250N L2: 270N L3: 280N	P
	Steel screws are fastened three times at the terminals, torque of 1,2 times value specified by manufacturer or value of Table 111	38,4Nm	P
	If measured values too low, dynamic test in accordance with 8.5.5.1	See 8.5.5.1	P
	Contact pieces not have moved to affect the further use		P
	Insulating mounting part no broken and no show any signs of cracks		P
8.10	Verification of non-deterioration of contacts (Sample: #02)		--
8.10.1	Arrangement of the fuse		--
	Figure 301 and Figure 302		P
	for lug terminals, torque in Table 111.....	32Nm	—
	Insulation of conductors removed over the whole length		P
8.10.1.2	Direct terminal clamps		--
	Test performed on 9 terminal clamps of three fuse-rails	No such terminal clamps	N/A
	Distance between fuse-rails centres of at least three times e2 (see Figure 101)		N/A
	Torque of tightened of screws	Nm	—
	Conductor cross-section	mm ²	—
8.10.2	Test method		--
	Test current (A) for load period	313A	P
	Duration (s) of load period	45min	P
	Duration (s) of non-load period	18min	P
	Test voltage (V)	Convenient low voltage	—

IEC 60269-2			
Clause	Requirement + Test	Result - Remark	Verdict
	a) Test of 50 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	P
	b) Test of 250 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	P
	c) Test of 500 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	N/A
	d) Test of 750 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	N/A
8.10.2.1	Contacts		--
	Points between voltage drop is measured (A and B in Figure 106)		P
	Withdrawal force (Table 118); measured force after 250 cycles (N)	L1: 270N L2: 240N L3: 250N	P
	Withdrawal force (Table 118); measured force after 750 cycles (N)	1) 2) 3)	N/A
	If measured values too low, test of 8.5.5.1		P
8.10.2.2	Direct terminal clamps	No such terminal clamps	--
	Points between voltage drop is measured (Figure 110)		N/A
	Test sequence for all types conductors (see Table 116)	(see appended table)	N/A
	Verification of temperature rise (see 8.3.4.1) (see figure 110)		N/A
8.10.3	Acceptability of test results		--
8.10.3.1	Contacts		P
	Limit value after 250th cycle \leq 15%	1,72%	P
	Limit value after 500th cycle \leq 30%		N/A
	Limit value after 750th cycle \leq 40%		N/A
	Difference between last and first measurement of temperature rise less than 20 K	3K (max.)	P
8.10.3.2	Direct terminal clamps	No such terminal clamps	--

IEC 60269-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Permissible tolerance for resistance Rcl0 for Al conductors : $R_{cl0\ max} \leq 2 R_{cl0\ min}$		N/A
	Permissible changes of the resistance from R cl 50 to R cl 750 : see Table 117		N/A
	Copper or cleaned aluminium conductors		N/A
	Uncleaned aluminium conductors		N/A
	Change from 50th to 250th cycle		N/A
	Change after 250th to 500th cycle		N/A
	Change after 500th to 750th cycle		N/A
	Change between 50th to 750th cycle		N/A
	Temperature rise at test spot F < 75K		N/A
8.11.1.2	Mechanical strength of the fuse-base (Sample: #02)	After Clause 8.10.1.1	--
	Contact force are tested on all three phases of a new fuse-rail		P
	Test-link inserted three times in the fuse-base (Dimensions of blade contacts see Figure 101) (Withdrawal force F lied within limits in Table118)	Limits: 110~350N Measured: L1: 270N L2: 240N L3: 250N	P
	Steel screws are fastened three times at the terminals, torque of 1,2 times value specified by manufacturer or value of Table 111	38,4Nm	P
	If measured values too low, dynamic test in accordance with 8.5.5.1	See 8.5.5.1	P
	Contact pieces not have moved to affect the further use		P
	Insulating mounting part no broken and no show any signs of cracks		P
8.5.5.1	Verification of peak withstand current of a fuse-base (Sample: #02)		--
	Covered by verification of non-deterioration of contacts according to 8.10	Not covered	N/A
	Measured values of withdrawal forces according to 8.10.2.1 are below the values in Table 118, verification of peak withstand current according to 8.5.5.1.1 of fuse system C		N/A
8.5.5.1.1	Arrangement of the fuse		--

IEC 60269-2			
Clause	Requirement + Test	Result - Remark	Verdict
	three-phase arrangement cut-off currents are below the values given in Table 112 : Test set-up is given in figure 302 : Cross-section of busbars (Figure 302) :	See test result on the report: 180301688SHA-001	P
8.5.5.1.2	Test method		--
	fuse-base 1 (Figure107) resilient spring travel is limited to elastic range : contacts opened up three times :		P
	fuse-base 2 (see 8.11.1.2) Fmax according to Table 118	Tested on the same fuse-base	P

8.3	Verification of temperature rise and power dissipation (Sample: #03)		--
8.3.1	Arrangement of the fuse		--
	Tightened by torque (Nm) :	32	—
8.3.2	Measurement of the temperature rise	See test result on the report: 180301688SHA-001	--
	Protective covers and fuse-carriers as provided by manufacturer mounted :		P
8.11.1.1	Mechanical strength of fuse-holders (Sample: #03)		--
	Test set-up subjected to temperature rise test at rated current :	250A Terminals:44K max.	P
	fuse-link or fuse-carrier are withdrawn and inserted into fuse-base 100 times :	100 times	—
	All parts are intact and function normally		P
	Test set-up subjected to further temperature rise test at rated current (values obtained are not more than 5 K or 15 % above the values from temperature-rise test prior)..... :	250A Terminals:47K max.	P
8.3	Verification of temperature rise and power dissipation (Sample: #03)	After clause 8.11.1.1	--
8.3.1	Arrangement of the fuse		--
	Tightened by torque (Nm) :	32	—

IEC 60269-2			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.2	Measurement of the temperature rise	See test result on the report: 180301688SHA-001	--
	Protective covers and fuse-carriers as provided by manufacturer mounted		P
8.9	Verification of resistance to heat (Sample: #03)		--
	Tests apply to fuse-link and fuse-base		P
	Fuse-holder with fuse-links having maximum power dissipation are cyclically loaded as pre-treatment...	100h On-period: 3h Off-period: 18min 400A	P
	After cooling to normal temperature breaking capacity tested at I1 (see 8.5)	I1 =690V/50kA See clause 8,5 below	P
	Fuse-links with organic material Fuse-holder with fuse-links having maximum power dissipation are cyclically loaded as pre-treatment....		N/A
	After cooling to normal temperature breaking capacity tested at I1 and I5 (see 8.5)	I1 = I5 =	N/A
8.5	Verification of the breaking capacity (Samples: #03)	According to IEC 60269-1	--
8.5.1	The test arrangements as specified in 8.1.4		P
8.5.2	Characteristics of the test circuit as specified		P
	Scheme of test circuit (see Figure 5)		P
	Deviations form specified characteristics of test circuit		N/A
8.5.3	Measuring instruments		P
8.5.4	Calibration of test circuit		P
	Calibration oscillograms and their evaluation		P
8.5.6	The breaking-capacity tests made at an ambient air temperature of (20 ± 5) °C	20°C	P
	Breaking-capacity tests on a.c. fuses		--
8.5.5.1	Table 20, test No. 1 for "g" and "a" fuse-links (Sample: #03)		P
	Rated breaking capacity of the fuse-links (kA), at voltage (V)	690V/50kA	-
	Rated current (A) of the fuse-links	250A	P

IEC 60269-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Prospective current I_1 (kA) equal to rated breaking capacity within a tolerance of + 10%, - 0%	730V/50,5kA	P
	Power factor	0,19	P
	Initiation of arcing after voltage zero: within 40° - 65° for sample 1 and within 65° - 90° for sample 2 and 3, or	65° - 90° for peak withstand current of a fuse-holder. Measured: 62°	P
	for sample 1) arcing after voltage zero within 0° + 10°, - 0°		N/A
	Power-frequency recovery voltage: voltage (V) i.e (%) of rated voltage within 105% + 5%, - 0% of the rated voltage or 110% + 5%, - 0% of the rated voltage	730V	P
	Cut-off current (kA)	#03) 29,5	P
8.5.8	Acceptability of No. 1 test results		P
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		P
	b) fuse-links operated without external effects or damage to the components of the complete fuse		P
	c) no permanent arcing, flashover or ejection of dangerous flames		P
	d) no damage of fuse components hindering from their further use		P
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		P
	f) fuse-link remains in one piece before its removal from the fuse- carrier		P
	g) resistance (M Ω) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases :		N/A
8.9.1	Fuse-base		--
	test below apply if it is not obvious that components are not affected adversely by given temperature and withdrawal forces		P
8.9.1.1	Test arrangement		--
	Figure 105 and 108		P
	Test se-up in heating chamber		P
8.9.1.2	Test method		--
	Temperature of (80+5)°C for 2 h	80°C	P
	160% rated current for 2 h.....	160% $I_n = 400A$	P
	Test voltage	Any convenient voltage	—

IEC 60269-2			
Clause	Requirement + Test	Result - Remark	Verdict
	3 min after switching off tensile force Fmax (see Table 118) exerted for 15 s	Fmax = 350N	P
8.9.1.3	Acceptability of test results		--
	Contact pieces not have moved to affect the further use		P
	Dimensions of Figure 301 are considered		P
	Insulating mounting part no broken and no show any signs of cracks		P
8.11.2.4	Non-deterioration of insulating parts of fuse-link and fuse-base (Sample: #03)		--
8.11.2.4.1	Test method		--
	One fuse-rail is tested	One fuse-rail	—
	Period 168 h	168h	—
	for equipment comprising moulded elements to support live parts (150±5)°C	150°C	—
	for covers (100±5)°C	100°C	—
	Period greater than 1 h	1h	—
	for sealing compounds; stability of marking(150±5)°C		—
	After cooling to ambient temperature the following are tested.		P
	Fuse-links: breaking capacity with I1 and I2		N/A
	Fuse-base: mechanical strength in accordance with 8.11.1.2		P
8.11.2.4.2	Acceptability of test results		--
	Not have changed of positions of fuse-base contacts to correct functioning		P
	No fracture nor any signs of fracture on insulating body with terminals		P
	Mechanical strength of cemented joints not impaired		P
	Sealing compounds not shifted to extent permitting live parts to exposed		N/A
	Fuse-links operate correctly		N/A
	Marking are durable and easily legible		P
8.11.1.2	Mechanical strength of the fuse-base (Sample: #03)		--

IEC 60269-2			
Clause	Requirement + Test	Result - Remark	Verdict
	Test-link inserted three times in the fuse-base : (Dimensions of blade contacts see Figure 101) (Withdrawal force F lied within limits in Table118)	Limits: 110~350N Measured: L1: 250N L2: 270N L3: 250N	P
	Steel screws are fastened three times at the terminals, torque of 1,2 times value specified by manufacturer or value of Table 111	38,4Nm	P
	Contact pieces not have moved to affect the further use		P
	Insulating mounting part no broken and no show any signs of cracks		P

IEC 60269-2			
Clause	Requirement + Test	Result - Remark	Verdict

APPENDIX 1

8.10.2	TABLE: Verification of non-deterioration of contacts									
	ambient air temperature (°C)					22				—
	sample No. 2(contacts)									
	L1-1	L1-2	L2-1	L2-2	L3-1	L3-2				
T 1 (K)	36	31	36	28	32	26				
ΔU initial	-	-	-	-	-	-				
Rcl 0	-	-	-	-	-	-				
ΔU 50	6,97m V	6,93m V	6,91m V	6,87m V	6,83m V	6,92m V				
Rcl 50(m Ω)	0,232	0,229	0,228	0,225	0,224	0,230				
ΔU 250	7,08m V	7,04m V	7,09m V	7,02m V	7,04m V	7,06m V				
Rcl 250(m Ω)	0,236	0,234	0,236	0,231	0,233	0,238				
T 2 (K)	-	-	-	-	-	-				
ΔU 500	-	-	-	-	-	-				
Rcl 500	-	-	-	-	-	-				
ΔU 750	-	-	-	-	-	-				
Rcl 750	-	-	-	-	-	-				
T 3 (K)	-	-	-	-	-	-				

T 1: Initial temperature rise / T 2: temperature rise after 250 cycles / T 3: final temperature rise

**Photo of sample:
See report 180301688SHA-001**