



TEST REPORT
IEC 60947-3

Low-voltage switchgear and controlgear

Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units

Report Reference No.: V160013

Tested by (name + signature).....:	LIN SHIFANG/CHEN ZHOU	
Approved by (name + signature).....:	WANG JIANXIN	

Date of issue : Aug. 7, 2012

IEC 60947-3:2008 (Third Edition) + A1:2012 in conjunction with
IEC 60947-1:2007 (Fifth Edition) + A1:2010

Test conclusion : Refer to the content of the report.

Testing Laboratory.....: Low-voltage Apparatus Laboratory (Wenzhou) of the Academy of Science and Technology for Inspection and Quarantine
Address.....: 699 Jixian Road, Economic and Technological Development Zone, Ruian, Zhejiang, China
Post code.....: 325200
Tel/Fax.....: +86 0577-65158685 / +86 0577-65158686
Email: ddsys@wz.ziq.gov.cn



Applicant's Name: Barfuse Electric Co.,Ltd.
Address: No. 15, Yonghe 3rd Road, Industry Function Zone, Chengdong St., Yueqing, Zhejiang, China



Test item description

Trademark: /
Manufacturer: Barfuse Electric Co.,Ltd.
Model and/or type reference: /

General remarks

This report is not valid without official seal and signatures.
The test results presented in this report relate only to the object tested.
This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.
Any objection should be raised to the testing laboratory in 15 days since the day this report be received.

Photos:



Summary of testing:

The following tests were done on the samples.

	Sub-clause	Sample number
Test according to sub-clause	8.3.7.1	#1
	8.3.7.2	#1
	8.3.7.3	#1
	8.3.7.4	#1

Test item particulars..... :	
- method of operation..... :	Single pole operated three pole switches
- suitability for isolation..... :	suitable
- degree of protection..... :	/
- number of poles..... :	3
- kind of current..... :	AC
-in the case of a.c., number of phases and rated frequency..... :	3/50Hz
- number of positions of the main contacts (if more than two)..... :	/
-breaking arrangement for fused devices..... :	single break
Rated and limiting values, main circuit..... :	/
- rated operational voltage U_e (V)..... :	415
- rated insulation voltage U_i (V)..... :	/
- rated impulse withstand voltage U_{imp} (kV)..... :	/
- conventional free air thermal current I_{th} (A)..... :	250
- conventional enclosed thermal current I_{the} (A)..... :	/
- rated operational current I_e (A)..... :	250
- rated uninterrupted current I_u (A)..... :	/
- rated frequency (Hz)..... :	50Hz
- utilization category..... :	/
Short-circuit characteristic..... :	/
- rated short-time withstand current I_{cw} (kA)..... :	/
- rated short-time making capacity I_{cm} (kA)..... :	/
- rated conditional short-circuit current..... :	80kA
Control circuits..... :	/
Auxiliary circuits..... :	/
Relays and releases..... :	/
Co-ordination with short-circuit protective devices..... :	/
- kind of protective device..... :	/

Possible test case verdicts:

- test case does not apply to the test object..... : N/A
- test object does meet the requirement..... : P (Pass)
- test object does not meet the requirement..... : F (Fail)

Testing..... :

Date of receipt of test item..... : 2016-12-13

Date (s) of performance of tests..... : 2016-12-14

General remarks:

The test results presented in this report relate only to the object tested.
This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma / point is used as the decimal separator.

Manufacturer's Declaration per sub-clause 4.2.5 of IEC60067-2:

The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided..... :

Yes
 Not applicable

When differences exist; they shall be identified in the General product information section.

Name and address of factory (ies)..... :

General product information:

Ue=AC415V
Ie=AC250V

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7	TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY		
8.3.7.1	Overload test		P
	ambient temperature 10-40 °C	20°C	—
	test enclosure W x H x D (mm x mm x mm)		—
	material of enclosure		—
	test current 1,6xI _{th} e or 1,6xI _{th} (A)	401.3A	—
	cable/busbar cross-section (mm ²) / length (mm) ...	120mm ² / 2000mm	—
	Fuse-link details:		P
	- manufacturer's name, trademark or identification mark	SIEMENS	—
	- rated current (A)	250A	—
	- power loss (W)	/	—
	- rated breaking capacity (kA)	120kA	—
	- time duration of the overload test (s)	31.5s	—
	Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed		P
	Required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	The equipment has not undergone any impairment hindering such operation		P
8.3.7.2	Dielectric verification		P
	test voltage: 2*U _e with a minimum of 1000V~	1000V	—
	No flashover or breakdown		P
8.3.7.3	Leakage current		P
	test voltage (1,1 U _e) (V)	457.0V	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole		N/A
	Leakage current (other utilization categories) ≤ 2 mA/pole	0.005mA	P
8.3.7.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark	SIEMENS	—
	- manufacturer's model or type reference	NH1-gG	—
	- rated current (A)	250A	—

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	- power loss (W)	/	—
	- rated breaking capacity (kA)	120kA	—
	Fuse links aged during the overload test are replaced by new fuse-links.....		P
	- conductor cross-section (mm ²)	120mm ²	—
	- test current I _e (A)	250A	—
	Measured temperature-rise.....	see appended table 8.3.7.4	P

8.3.7.4	TABLE: Temperature-rise (measurements)		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals	38.6	80	
Manual operating means: metallic / non-metallic	/	/	
Parts intended to be touched but not hand-held: metallic / non-metallic	/	/	
Parts which need not be touched during normal operation	33.3	60	
supplementary information:			

