



**TEST REPORT**  
**IEC 60947-3**

**Low-voltage switchgear and controlgear**

**Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units**

**Report Reference No.:**V160016

Tested by (name + signature).....:	LIN SHIFANG/CHEN ZHOU	
Approved by (name + signature).....:	WANG JIANXIN	

Date of issue : Aug. 7, 2012

IEC 60947-3:2008 (Third Edition) + A1:2012 in conjunction with  
IEC 60947-1:2007 (Fifth Edition) + A1:2010

**Test conclusion** : Refer to the content of the report.

**Testing Laboratory**.....: Low-voltage Apparatus Laboratory (Wenzhou) of the Academy of Science and Technology for Inspection and Quarantine  
Address.....: 699 Jixian Road, Economic and Technological Development Zone, Ruian, Zhejiang, China  
Post code.....: 325200  
Tel/Fax.....: +86 0577-65158685 / +86 0577-65158686  
Email: ddsys@wz.ziq.gov.cn



**Applicant's Name** .....: Barfuse Electric Co.,Ltd.  
Address .....: No. 15, Yonghe 3rd Road, Industry Function Zone, Chengdong St., Yueqing, Zhejiang, China

**Test item description**

Trademark .....: /  
Manufacturer: Barfuse Electric Co.,Ltd.  
Model and/or type reference .....: /

**General remarks**

This report is not valid without official seal and signatures.  
The test results presented in this report relate only to the object tested.  
This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.  
Any objection should be raised to the testing laboratory in 15 days since the day this report be received.

Photos:



**Summary of testing:**

The following tests were done on the samples.

	<b>Sub-clause</b>	<b>Sample number</b>
<b>Test according to sub-clause</b>	<b>8.3.6.2.1</b>	<b>#1</b>
	<b>8.3.6.3</b>	<b>#1</b>
	<b>8.3.6.4</b>	<b>#1</b>
	<b>8.3.6.5</b>	<b>#1</b>

<b>Test item particulars</b> ..... :	
- method of operation.....	: Single pole operated three pole switches
- suitability for isolation.....	: suitable
- degree of protection.....	: /
- number of poles.....	: 3
- kind of current.....	: AC
-in the case of a.c., number of phases and rated frequency.....	: 3/50Hz
- number of positions of the main contacts (if more than two).....	: /
-breaking arrangement for fused devices.....	: single break
Rated and limiting values, main circuit..... :	
- rated operational voltage $U_e$ (V).....	: 415
- rated insulation voltage $U_i$ (V).....	: /
- rated impulse withstand voltage $U_{imp}$ (kV).....	: /
- conventional free air thermal current $I_{th}$ (A).....	: 250
- conventional enclosed thermal current $I_{the}$ (A).....	: /
- rated operational current $I_e$ (A).....	: 250
- rated uninterrupted current $I_u$ (A).....	: /
- rated frequency (Hz).....	: 50Hz
- utilization category.....	: /
Short-circuit characteristic..... :	
- rated short-time withstand current $I_{cw}$ (kA).....	: /
- rated short-time making capacity $I_{cm}$ (kA).....	: /
- rated conditional short-circuit current.....	: 80kA
Control circuits..... :	
Auxiliary circuits..... :	
Relays and releases..... :	
Co-ordination with short-circuit protective devices..... :	
- kind of protective device.....	: /

**Possible test case verdicts:**

- test case does not apply to the test object..... : N/A
- test object does meet the requirement..... : P (Pass)
- test object does not meet the requirement..... : F (Fail)

**Testing..... :**

**Date of receipt of test item..... :** 2016-12-26

**Date (s) of performance of tests..... :** 2016-12-29

**General remarks:**

The test results presented in this report relate only to the object tested.  
This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

**Throughout this report a  comma /  point is used as the decimal separator.**

**Manufacturer's Declaration per sub-clause 4.2.5 of IEC60947-3:**

The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided..... :

**Yes**  
 **Not applicable**

**When differences exist; they shall be identified in the General product information section.**

**Name and address of factory (ies)..... :**

**General product information:**

Ue=AC415V  
Ie=AC250V


IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT		
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	SIEMENS	—
	- manufacturer's model or type reference .....	NH1-gG	—
	- rated voltage (V) .....	415V	—
	- rated current (A) .....	250A	—
	- rated breaking capacity (kA) .....	80kA	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 x Ue) (V) .....	440	—
	test current (kA) .....	82.20	—
	rated frequency (Hz) .....	50	—
	power factor .....	0.17	—
	Time constant (ms).....	/	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (kA) .....	L1: 3.315 L2: 25.30 L3: 24.58	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 276.8 L2: 370100 L3: 209300	—
	Fuse protected short-circuit making		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....		—
	- point at which the measurement is made .....	C phase	—
	- test speed during the fuse protected short-circuit making (m/s) .....	0.375	—
	- max. let-through current (kA) .....	L1: 0 L2: 19.96 L3: 20.03	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: L2: 319300 L3: 378300	—
8.3.6.3	Dielectric verification		P
	test voltage: 2*Ue with a minimum of 1000V~.....	1000V	—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	test voltage (1,1 Ue) (V) .....	457.0V	—
	Leakage current (utilization categories AC- 20A, AC- 20B, DC- 20A and DC- 20B) $\leq 0,5$ mA/pole .....		N/A
	Leakage current (other utilization categories) $\leq 2,0$ mA/pole .....	0.005mA	P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	SIEMENS	—
	- manufacturer's model or type reference .....	NH1-gG	—
	- rated current (A) .....	250A	—
	- power loss (W) .....	/	—
	- rated breaking capacity (kA) .....	80kA	—
	- conductor cross-section (mm <sup>2</sup> ) .....	120mm <sup>2</sup>	—
	- test current Ie (A) .....	250A	—
	Measured temperature-rise.....	see appended table 8.3.6.5	P

8.3.6.5	TABLE: Temperature-rise (measurements)		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals	36.1	80	
Manual operating means: metallic / non-metallic	15.2	35	
Parts intended to be touched but not hand-held: metallic / non-metallic	31.7	50	
Parts which need not be touched during normal operation	30.9	60	
supplementary information:			

### Record curves for short-circuit test

#### Three phases prospective Curve



Curve No. : CW-F-3P-415V80000A0.2


Test voltage: 440V

Ia= 81.73kA  
 Ib= 82.82kA  
 Ic= 82.05kA  
 average current I= 82.20kA

I<sub>pmax</sub>= 182.2kA

Cosa= 0.183  
 Cosb= 0.165  
 Cosc= 0.154  
 average Cos Φ = 0.167

Fuse protected short-circuit withstand a)withstand test



Curve No.: V160016#1-1  
 Description of product :  
 switch-disconnect  
 Specification of product:  
 3P/250A  
 Sample No.: #1  
 Test sequence: O  
 Test voltage: 440V  
 Prospective current: 82.20kA  
 Prospective PF: 0.167


I<sub>pa</sub> = 3.315kA  
 I<sub>pb</sub> = 25.30kA  
 I<sub>pc</sub> = 24.58kA

I<sup>2</sup>t<sub>a</sub> = 276.8 AAS  
 I<sup>2</sup>t<sub>b</sub> = 386.1kAAS  
 I<sup>2</sup>t<sub>c</sub> = 209.3kAAS

Make-break	time	T <sub>ta</sub> =
	2.680ms	
Make-break	time	T <sub>tb</sub> =
	6.477ms	
Make-break	time	T <sub>tc</sub> =
	1.745ms	

Arcing time T<sub>ra</sub> = 2.680ms  
 Arcing time T<sub>rb</sub> = 5.410ms  
 Arcing time T<sub>rc</sub> = 910.0μs

Fuse protected short-circuit withstand b) Making test



Curve No.: V160016#1-2  
 Description of product :  
 switch-disconnect  
 Specification of product:  
 3P/250A  
 Sample No.: #1  
 Test sequence: M  
 Test voltage: 440V  
 Prospective current: 82.20kA  
 Prospective PF: 0.167

$I_{pa}$ = --A  
 $I_{pb}$ = 19.96kA  
 $I_{pc}$ = 20.03kA

$I^2t_a$ = --AAS  
 $I^2t_b$ = 319.3kAAS  
 $I^2t_c$ = 378.1kAAS

Make-break time  $T_{ta}$ = --ms  
 Make-break time  $T_{tb}$ = 6.960ms  
 Make-break time  $T_{tc}$ = 6.820ms

Arcing time  $T_{ra}$ = --ms  
 Arcing time  $T_{rb}$ = 6.960ms  
 Arcing time  $T_{rc}$ = 6.820ms

**List of test equipment used:**

(Note: This is an example of the required attachment. Other forms with a different layout but containing similar information are also acceptable.)

Clause	Measurement / testing	Testing / measuring equipment / material used	Range used	Calibration date
8.3.6.2.1	Fuse protected short-circuit withstand	AC A200kA Short-circuit System ESR001	10kA~200kA	2018-1-16
		Torque driver ESR052	0-50Nm	2018-1-16
8.3.6.3	Dielectric verification	Withstand Voltage Device ESR070	AC Output 0.05kV~5kV; AC Leakage Current 0.01mA~110mA; DC Output 0.05kV~6kV;DC Leakage Current 0.01mA~11mA	2018-1-16
8.3.6.4	Leakage current	Withstand Voltage Device ESR070	AC Output 0.05kV~5kV; AC Leakage Current 0.01mA~110mA; DC Output 0.05kV~6kV;DC Leakage Current 0.01mA~11mA	2018-1-16
8.3.6.5	Temperature-rise verification	Data Acquisition Device( Temperature) ESR028-01	0~400°C	2018-1-14
		63KVA three phases multi-magnetic transformer ESR080	200A-4000A	2018-1-14