

# Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out. This verification is part of the full test report(s) and should be read in conjunction with them.

Applicant Name & Address:	YUEQING BARFUSE ELECTRIC CO., LTD Yonghe san Rd, no.15, Chengdong Industry zone, Yueqing, Zhejiang, China
Product Description:	STRIP TYPE FUSE RAIL
Ratings & Principle Characteristics:	Un=690V, In=250A, Ip=690V/50kA, System C
Models:	BTR2-250A
Relevant Standards	IEC 60269-1:2006 + A1:2009 + A2:2014 and IEC 60269-2:2013 + A1:2016
Verification Issuing Office:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou, China
Date of issue:	9 May 2018
Test Report Number(s):	180301688SHA-001 and 180301688SHA-002



---

## Signature

**Name: Jackey Xie**  
**Position: Director**  
**Issuing Office: Guangzhou**  
**Date: 9 May 2018**

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.