


TEST CERTIFICATE

Issued to: YUEQING BARFUSES ELECTRIC CO., LTD.
No. 15, Yonghe 3 Road, Chengdong Industry Zone, Yueqing, Wenzhou, Zhejiang,
China

For the product: Low-voltage switchgear and controlgear assembly - Busbar

Trade name: BARFUSES  **BARFUSES**
BATTLE FOR SAFETY

BFSe

Type/Model: BP1-250

Ratings: I_{nA} 250 A, U_e 380/400 V, U_i 690 V, U_{imp} 4 kV, 50/60 Hz
 I_{cw} 25 kA - 0,2 s, 22,3 kA - 0,25 s, 10 kA - 1 s
For more details see annex

Manufactured by: YUEQING BARFUSES ELECTRIC CO., LTD.
No. 15, Yonghe 3 Road, Chengdong Industry Zone, Yueqing, Wenzhou, Zhejiang,
China

Subject: Clauses 10.4, 10.9, 10.10.2.3.7a), 10.11

Requirements: IEC 61439-2: 2011, EN 61439-2: 2011
Clauses 10.4, 10.9, 10.10.2.3.7a), 10.11

Remark: I_{nA} 250 A was tested without enclosure (open-type assembly)


This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 3309992.02-INC, dated 5 September 2016.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 5 September 2016

Number: 3309992.101

DEKRA Certification B.V.



H.L. Schendstok
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

Overview of product evaluation according to IEC/EN 61439-2:

IEC/EN 61439-2 Clause	Clause description	Tested ratings	Results
10.4	Clearances and creepage distances	Clearances > 3 mm, based on $U_{imp} = 4 \text{ kV}$; Creepage distances > 10 mm, based on $U_i = 690 \text{ V}$, pollution degree 3, material group IIIa.	Pass
10.9	Dielectric properties		
10.9.2	Power-frequency withstand voltage	$U_i 690 \text{ V}$	Pass
10.9.3	Impulse withstand voltage	$U_{imp} 4 \text{ kV}$	Pass
10.9.4	Testing of enclosures made of insulating material		Pass
10.10	Verification of temperature rise		
10.10.2.3.7 a)	Verification of the main busbars separately	Main busbar - 250 A (BP1-250 6W) - 250 A (BP1-250 60W)	Pass
10.11	Short-circuit withstand strength	I_{cw} for 3-phase main circuit: 25 kA - 0,2 s 22,3 kA - 0,25 s 10 kA - 1 s	Pass

Product details:


	Description
Main busbar	3 phases, copper 20 mm x 3 mm (external terminal) 25 mm x 3 mm (main busbar)
Number of outgoing ways	3-phase, 6 ways to 60 ways

Applicant : YUEQING BARFUSES ELECTRIC CO., LTD
No. 15, Yonghe 3 Road, Chengdong Industry Zone, Yueqing, Wenzhou,
Zhejiang,
China

Application Date : 19 May 2016

Order Number : 3309992.00-INC

Product : Low-voltage switchgear and controlgear assembly

Trade name : BARFUSES  **BARFUSES**
BATTLE FOR SAFETY

BFSe

Type/Model : BP1-250


Arnhem, 5 September 2016


Manufacturer/
Production sites : YUEQING BARFUSES ELECTRIC CO., LTD
No. 15, Yonghe 3 Road, Chengdong Industry Zone, Yueqing, Wenzhou,
Zhejiang,
China

Subject : Clauses 10.4, 10.9, 10.10.2.3.7a), 10.11

Requirements : IEC/EN 61439-2: 2011
Clauses 10.4, 10.9, 10.10.2.3.7a), 10.11

Conclusion : The product complies with the specified requirements

Tested by : Ken Peng 

Checked by : F.S. Strikwerda 

Kpe

0509-16

© DEKRA Certification B.V. All rights reserved

Products may only be provided with a quality mark or put on the market as approved if DEKRA Certification B.V. has explicitly granted the right to carry a quality mark.

DEKRA Certification B.V. and/or its subsidiaries are not liable for any direct or indirect, incidental or consequential loss originating through or because of the use of the information or data from this document or due to the impossibility of using that information or data.

The contents of this report may not be made available to a third party other than as an entity provided with the aforementioned designations with respect to copyrights and liability.

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396

Table of contents

1	Subject	3
2	Interface characteristics	3
2.1	Tested characteristics	3
2.2	Declared characteristics by manufacturer	3
3	Object identification	4
4	Summary of design verifications	6
5	General Items	7
6	Design verification	8
6.1	Performance	8
6.1.1	Clearances and creepage distances	8
6.1.2	Dielectric properties	8
6.1.3	Verification of temperature-rise	9
6.1.4	Short-circuit withstand strength	11
Appendix A	Temperature rise tests	12
A.1	Temperature rise test results	12
A.2	Position of thermocouples for temperature rise setup	14
A.3	Photos of temperature rise tests	16
Appendix B	Short-circuit withstand tests	18
B.1	Short-circuit withstand test results	18
B.2	Test circuit diagram	20
B.3	Oscillograms	21
B.4	Photos of short-circuit withstand tests	25
Appendix C	Product information	29
C.1	Drawings	29

1 Subject

Low-voltage switchgear and controlgear assembly - Busbar

Product information

Trademark : BARFUSES



Type : BFSe
: BP1-250

2 Interface characteristics

2.1 Tested characteristics

Rated operational voltage (U_e)	: 380/400 V
Rated insulation voltage (U_i)	: 690 V
Rated impulse withstand voltage (U_{imp})	: 4 kV
Rated current of the assembly (I_{nA})	: 250 A (for main busbar)
Rated short-circuit withstand strength (I_{cw} and I_{pk})	: 3-phase 25 kA - 0,2 s with a peak of 52,5 kA 3-phase 22,3 kA - 0,25 s with a peak of 46,8 kA 3-phase 10 kA - 1 s with a peak of 17 kA
Rated frequency (f_n)	: 50/60 Hz
Ambient Air Temperature	: -5 °C to +40 °C

Note: I_{nA} 250 A was tested without enclosure upon request from the manufacturer.

2.2 Declared characteristics by manufacturer

Stationary or movable	: Stationary
Type of construction	: Open-type assembly

Note:

1. Due to the fact that I^2t value and peak current value of 22,3 kA - 0,25 s I_{cw} rating are lower than the values of 25 kA - 0,2 s I_{cw} rating, 22,3 kA - 0,25 s can be claimed without actual testing.
2. ASSEMBLIES has a rated short-time withstand current not exceeding 10 kA r.m.s which is exempted from the verification of the short circuit withstand strength (IEC/EN 61439-1 clause 10.11.2).

3 Object identification




Photo 1: Sample BP1-250 6W




Photo 2: Sample BP1-250 60W




Photo 3: Inside view

The external dimensions are stated in the drawings included in this report. For components and drawings see Appendix C.

4 Summary of design verifications

Performance:

Clause 10.4	Clearances and creepage distances
Clause 10.9	Dielectric properties
Clause 10.10	Verification of temperature rise
- Clause 10.10.2.3.7a)	Verification of the main busbars separately
Clause 10.11	Short-circuit withstand strength

All other clauses are not required by client.

5 General Items

Location of the tests

Clauses 10.9.2, 10.10, 10.11 were carried out at Zhejiang Fangyuan Electrical Equipment Testing Co., Ltd.
- West Zhonghuan Road, Jiaxing City, Zhejiang Province, China.

Others were carried out at DEKRA Testing Services (Zhejiang) Co., Ltd., - No. 5, Changjiang Road, Great Bridge Industrial Park, North Baixiang, Wenzhou, China.

Tests were carried out by

Huang Fang Zhejiang Fangyuan Electrical Equipment Testing Co., Ltd, Jiaxing, China

Manufacturer's representatives during tests

Li Jietong YUEQING BARFUSES ELECTRIC CO., LTD, China
Yan Zhengkuan YUEQING BARFUSES ELECTRIC CO., LTD, China

The tests were witnessed by

Ken Peng DEKRA Testing Services (Zhejiang) Co., Ltd., Wenzhou, China
King Wang DEKRA Testing Services (Zhejiang) Co., Ltd., Wenzhou, China

General notes on tests

The frequency during the tests was 50 Hz.

The conclusion and results stated in this report are based on a non-recurrent examination of the sample(s) provided by the applicant.

The tests were conducted in June 2016 to October 2016.

6 Design verification

6.1 Performance

6.1.1 Clearances and creepage distances

The verification of the creepage and clearance distances is done in conformity with IEC/EN 61439-2, clause 10.4.

6.1.1.1 Clearances

The clearances are checked with the impulse withstand voltage $U_{imp} = 4 \text{ kV}$. Further the clearances are measured in respect to the $U_{imp} = 4 \text{ kV}$. Clearances shall be not less than 3 mm.

No clearances less than 3,6 mm were observed.

Result: Pass

6.1.1.2 Creepage distances

Creepage distances are verified based on the specified insulation voltage of $U_i = 690 \text{ V}$, pollution degree 3 and material group IIIa. Creepage distances shall be greater than or equal to 10 mm.

No creepage distances less than 12,1 mm were observed.

Result: Pass

6.1.2 Dielectric properties

The verification of the dielectric properties by test is done in conformity with and IEC/EN 61439-2, clause 10.9.

Insulation voltage (U_i):	690 V
Impulse withstand voltage (U_{imp}):	4 kV

6.1.2.1 Power frequency withstand test

Verification according to IEC/EN 61439-2 clause 10.9.2

The assembly was subjected during 5 seconds to a high voltage test with a test voltage of 1890 Vac. No breakdown or flash-over occurred during the tests.

Both BP1-250 6W and BP1-250 60W were tested.

Test voltage between	Test voltage (V)	Result
L1 to L2/L3/metal plate	1890	Pass
L2 to L1/L3/metal plate	1890	Pass
L3 to L1/L2/metal plate	1890	Pass
Metal plate to L1/L2/L3	1890	Pass

Table 1: Power frequency test results

Result: Pass

6.1.2.2 Impulse withstand voltage

Verification according to IEC/EN 61439-2 clause 10.9.3

The assembly was tested for a rated impulse withstand voltage of 4 kV. The test voltage was 4,8 kV 1,2/50 μ s at sea level. The test impulse voltage was applied five times for each polarity at intervals of 1 second in the prescribed connections. No breakdown or flash-over occurred during the tests.

Both BP1-250 6W and BP1-250 60W were tested.

Test voltage between	Test voltage (kV)	Result
L1 to L2/L3/metal plate	4,8	Pass
L2 to L1/L3/metal plate	4,8	Pass
L3 to L1/L2/metal plate	4,8	Pass
Metal plate to L1/L2/L3	4,8	Pass

Table 2: Impulse withstand voltage test results

Result: Pass

6.1.2.3 Testing of enclosures made of insulating material

Verification according to IEC/EN 61439-2 clause 10.9.4

The outside of the busbar cover was covered by a metal foil over openings and joints. A test voltage of 2835 Vac was applied during 5 seconds between the foil and the interconnected live and exposed conductive parts within the assembly. No breakdown or flash-over occurred during the tests.

Both BP1-250 6W and BP1-250 60W were tested.

Result: Pass

6.1.3 Verification of temperature-rise**6.1.3.1 Verification of the main busbars separately**

The verification of the temperature-rise is done in conformity with IEC/EN 61439-2, clause 10.10.2.3.7a).

Test 6.1.2.1-1 test for BP1-250 6W

A temperature-rise test was conducted on the main busbar. During the test, the sample was placed in a test room, mounted on a frame, with wooden board behind.

The 50 Hz current source was connected by 3 m long PVC insulated copper cable of 120 mm² to the supply connection of the assembly. Per phase 1 cable was connected. The busbar was loaded with 250 A. The other side of the main busbar was connected with 3 m long PVC insulated copper cable of 120 mm² to the star point. Per phase 1 cable was connected.

The temperature-rises were measured by means of thermocouples, including the ambient temperature. All currents are kept constant until thermal equilibrium is reached.

Details of the temperature-rise verification are given in Appendix A. The tables in the appendix give the recorded temperature-rise values at steady state. The values do not exceed the maximum allowed temperature-rise limits.

Result: Pass

Test 6.1.2.1-2 test for BP1-250 60W

A temperature-rise test was conducted on the main busbar. During the test, the sample was placed in a test room, mounted on a frame, with wooden board behind.

The 50 Hz current source was connected by 3 m long PVC insulated copper cable of 120 mm² to the supply connection of the assembly. Per phase 1 cable was connected. The busbar was loaded with 250 A. The other side of the main busbar was connected with 3 m long PVC insulated copper cable of 120 mm² to the star point. Per phase 1 cable was connected.

The temperature-rises were measured by means of thermocouples, including the ambient temperature. All currents are kept constant until thermal equilibrium is reached.

Details of the temperature-rise verification are given in Appendix A. The tables in the appendix give the recorded temperature-rise values at steady state. The values do not exceed the maximum allowed temperature-rise limits.

Result: Pass

6.1.4 Short-circuit withstand strength

The verification of the short-circuit withstand strength by test is done in conformity with IEC/EN 61439-2, clause 10.11.

Details of the testing of the short-circuit withstand strength are given on sheets 1 and 2 in Appendix B. The appendix also shows photos and oscillograms of the short-circuit tests.

From data stated in Appendix B can be concluded that the short-circuit withstand strength complies with the specified values as given on page 3.

Schedule of tests:

BP1-250 6W:

Short-time withstand current (I_{cw}):

3 phases: $I_{cw} = 25 \text{ kA} - 0,2 \text{ s}$, 52,5 kA peak (osc. S1682603)

BP1-250 60W:

Short-time withstand current (I_{cw}):

3 phases: $I_{cw} = 25 \text{ kA} - 0,2 \text{ s}$, 52,5 kA peak (osc. S1682702)

Due to the fact that I^2t value and peak current value of 22,3 kA - 0,25 s I_{cw} rating are lower than the values of 25 kA - 0,2 s I_{cw} rating, 22,3 kA - 0,25 s can be claimed without actual testing.

Result: Pass

Appendix A Temperature rise tests

A.1 Temperature rise test results

Table 3: Temperature rise test results


Test no. 6.1.2.1-1				
Test object: BP1-250 6W				
Test current: 250 A				
Connection on supply side: 1 PVC insulated copper cable of 120 mm ² cross-section and 3 m length (each phase)				
Thermo-couple	Description	Phase	Temp rise [K]	Max. Allowed [K]
101	Incoming terminal of assembly (external terminal)	L1	42	70
102		L2	38	70
103		L3	35	70
104	Top of main busbar	L1	50	90
105		L2	40	90
106		L3	37	90
107	Bottom of main busbar	L1	54	90
108		L2	39	90
109		L3	34	90
110	Busbar cover, top	-	19	40
111	Busbar cover, bottom	-	24	40
Ambient temperature 27 °C				
1. Thermal class of electrical insulating material is 125 °C.				

Table 4: Temperature rise test results


Test no.	6.1.2.1-2			
Test object:	BP1-250 60W			
Test current:	250 A			
Connection on supply side: 1 PVC insulated copper cable of 120 mm ² cross-section and 3 m length (each phase)				
Thermo-couple	Description	Phase	Temp rise [K]	Max. Allowed [K]
101	Incoming terminal of assembly (external terminal)	L1	41	70
102		L2	47	70
103		L3	41	70
104	Top of main busbar	L1	46	90
105		L2	49	90
106		L3	44	90
107	Middle of main busbar	L1	49	90
108		L2	60	90
109		L3	41	90
110	Bottom of main busbar	L1	44	90
111		L2	78	90
112		L3	31	90
113	Busbar cover, top	-	24	40
114	Busbar cover, middle	-	26	40
115	Busbar cover, bottom	-	15	40
	Ambient temperature 28 °C			
1. Thermal class of electrical insulating material is 125 °C.				

A.2 Position of thermocouples for temperature rise setup.

For test 6.1.2.1-1



For test 6.1.2.1-2



A.3 Photos of temperature rise tests




Photo 4: Temperature rise tests of BP1-250 6W





Photo 5: Temperature rise tests of BP1-250 60W

DEKRA Certification B.V.		TABLE WITH TEST RESULTS Short-circuit withstand tests			Date: 11 August 2016	Sheet: 1
Object Busbar BARFUSES BP1-250 6W I _{cw} : 25 kA at 400 V (3-phase incoming circuit)						
Osc no	Current				Test voltage	Remarks
	peak [kA]	rms [kA]	duration [ms]	thermal equivalent for 0,2 s [kA]	[V]	
Y16826 03	53,8 41,9 46,7	25,2 25,5 25,4	275	-	426 426 427	Prospective current 25 kA - 0,2 s on three phase at 400 V cosφ 0,22
3 phase under test						
S16826 03	51,9 40,3 44,0	24,5 24,6 24,2	232	26,4 26,5 26,1	426	No visible disturbance Test pass
Phase values are to be read: <div style="display: flex; justify-content: space-between; margin-top: 5px;"> A (Supply) → L1 object B (Supply) → L2 object C (Supply) → L3 object </div>						
Dielectric test at 1000 Vac - 5 s after test: No breakdown or flash-over occurred during the tests.						


DEKRA Certification B.V.		TABLE WITH TEST RESULTS Short-circuit withstand tests				Date: 1 August 2016	Sheet: 2
Object		Busbar BARFUSES BP1-250 60W I _{cw} : 25 kA at 400 V (3-phase incoming circuit)					
Osc no	Current				Test voltage	Remarks	
	peak [kA]	rms [kA]	duration [ms]	thermal equivalent for 0,2 s [kA]	[V]		
Y16827 02	54,1 42,4 46,3	25,4 25,7 25,3	275	-	426 426 426	Prospective current 25 kA - 0,2 s on three phase at 400 V cosφ 0,22	
3 phase under test							
S16827 02	50,4 40,3 42,6	24,3 24,5 24,1	230	26,1 26,3 25,8	426	No visible disturbance Test pass	
Phase values are to be read: <div style="margin-left: 40px;"> A (Supply) → L1 object B (Supply) → L2 object C (Supply) → L3 object </div>							
Dielectric test at 1000 Vac - 5 s after test: No breakdown or flash-over occurred during the tests.							

B.2 Test circuit diagram




B.3 Oscillograms

The oscillogram of prospective current





The oscillogram of prospective current



DK16-827
Y-25k-3Ph
Uab=426V
Ubc=426V
Uca=426V
Ia=25.4kA
Ib=25.7kA
Ic=25.3kA
Ipa=54.1kA
Ipb=42.4kA
Ipc=46.3kA
cosφ=0.22
Duration: 275. ms
Oscillogram NO:Y1682702

2016.08.01





B.4 Photos of short-circuit withstand tests



Photo 6: Before I_{cw} test of BP1-250 6W




Photo 7: After I_{cw} test of BP1-250 6W




Photo 8: Before I_{cw} test of BP1-250 60W






Photo 9: After I_{cw} test of BP1-250 60W

Appendix C Product information


C.1 Drawings




图纸编号:	BFS16CBP1001-250A	绘图:	
产品名称:	MCB分电盘	审核:	
制造商:	乐清市巴富斯电气有限公司	批准:	




图纸编号: BFS16CBP1002-250A	绘图:	
产品名称: MCB分电盘	审核:	
制造商: 乐清市巴富斯电气有限公司	批准:	




图纸编号:	BFS16SEP1001-250A	绘图:	
产品名称:	ICB分电盘	审核:	
制造商:	乐清市巴雷斯电气有限公司	批准:	







图样编号:	BF516SBP1002-250A	绘图:	
产品名称:	ICB分电盘	审核:	
制造商:	乐清市巴嘉斯电气有限公司	批准:	



图纸编号: BFS16SEP1003-250A	绘图:	
产品名称: MCB分电盘	审核:	
制造商: 乐清市巴富斯电气有限公司	批准:	



图样编号:	BFSI6SEF1004-250A	绘图:	
产品名称:	MCB分电盘	审核:	
制造商:	乐清市巴富斯电气有限公司	批准:	



图纸编号:	BFS16SBP1005-250A	绘图:	
产品名称:	MCE分电盘	审核:	
制造商:	乐清市巴富斯电气有限公司	批准:	

姓名	张明
性别	男
年龄	28岁
民族	汉族
籍贯	江苏省南京市
学历	大学本科
专业	计算机科学与技术
毕业院校	南京理工大学
学位	工学学士
职称	助理工程师
工作单位	南京软件研究所
联系电话	025-88888888
电子邮箱	zhangming@njust.edu.cn
身份证号	32010619900101XXXX
政治面貌	中共党员
健康状况	良好
婚姻状况	未婚
其他信息	